Innovative products

Acceptance certificate

Issue date:	23/02/2022
Reference number:	3882
Issue:	02
Innovative Product Owner:	Siderise Insulation Ltd Forge Industrial Estate, Maesteg, Bridgend, CF34 0AH.
Innovative Product name:	Siderise CT
Generic form:	Building component

NHBC Services Ltd has reviewed the following information (the System Manual) related to the Innovative Product supplied by the Innovative Product Owner:

- BBA Agrément Certificate 21/5978 Product Sheet 1, Issue 1 dated 24 January 2022

Relying on the information provided by the Innovative Product Owner, NHBC Services Ltd considers that the Innovative Product can meet NHBC Standards.

Additional requirements must be met in order for a new home to qualify for Buildmark cover. Buildmark cover for new homes will only be issued to Builders or Developers in accordance with the latest version of the NHBC Rules (a copy of which can be found at www.nhbc.co.uk).

This acceptance certificate is valid until such time as it is no longer published or authorised by NHBC. Readers are advised to check the validity and latest issue number of this Certificate by either referring to our website at www.nhbc.co.uk/accepts or contacting NHBC directly.

Issued by:

Innovation Services Manager

NHBC Services Ltd

NHBC Services Limited is a private company registered in England and Wales. Registered number 03067703. Registered office: NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire MK5 8FP. Tel: 0344 633 1000 www.nhbc.co.uk

Acceptance certificate

Description, Scope and intended use

The System is formed from straight sections with a length of 1m, and a 50mm overlap joint. It is manufactured to 150mm high triangular sections with an additional 50mm 'flange' to the back wall.

The width is manufactured to suit the project specific cavity size with typical cavity widths of 100mm – 350mm.

Internal and external corners are formed by cutting the straight length to suit the angle, and then taped at the cut with a proprietary foil tape. Preformed stop ends are used at wall terminations.

The System is intended to prevent water ingress in LSF structures over 18m in height where combustible materials are restricted from use.

Extent of review for NHBC Warranty on NHBC Registered Sites

NHBC Services Ltd has undertaken a technical review of the System Manual as set out in line with the NHBC Accepts Technical Document for Innovative Products.

The NHBC Accepts Service is intended solely to provide confidence that the Innovative Product meets NHBC Standards and is not intended as evidence of performance for any other purpose. Appraisal of the Innovative Products against building regulations is not carried out as part of this Service.

Exclusions and Limitations

This Acceptance Certificate is made out solely to the System Owner. To the fullest extent permitted by law, we do not accept or assume responsibility to anyone other than the System Owner arising out of, or in connection with, this Acceptance Certificate.

Exclusions and limitations are set out in the System Manual. Additional considerations in the use of the Innovative Product include:

- The System does not constitute a cavity barrier against the penetration of smoke and flame; therefore, it should be used in conjunction with cavity barriers.