



CERTIFICATE OF APPROVAL No CF 6028

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

SIDERISE INSULATION LIMITED

Forge Industrial Estate, Maesteg,
Bridgend, CF34 0AZ
Tel: 01656 730833 Fax: 01656 812509

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Siderise 'RV' linear joint seals
used as cavity barrier seals
(BS EN 1366-4:2006+A1:2010)

TECHNICAL SCHEDULE

TS 39 Fire Resisting Cavity
Barrier Systems

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued: 16th August 2021
Audit Test Frequency: Annually
Valid to: 15th August 2026



CERTIFICATE No CF6028 SIDERISE INSULATION LIMITED

Siderise 'RV' linear joint seals used as cavity barrier seals - BS EN 1366-4:2006+A1:2010

This Certificate of Approval relates to the fire resistance of Siderise 'RV' linear joint seals used as cavity barrier seals when used in the following application.

Application
Between concrete to concrete/masonry, or masonry to masonry/concrete substrates

This approval uses the Integrity and Insulation criteria defined in BS EN 1366-4:2006+A1:2010.

This approval also relates to the use of Siderise 'RV' linear joint seals used as cavity barrier seals for the fire protection of linear joint (cavity barrier) gaps installed between a minimum 150mm thick, concrete or masonry (twin leaf cavity wall) substrates of a density $\geq 670\text{kg/m}^3$. The Siderise 'RV' linear joint seals used as cavity barrier seals, which comprises a foil faced stone mineral lamella core, is formed in 1200mm long sections, and is provided in a range of thicknesses. The detailed scope is given in the Approval Matrix included in this Certificate. This shows the thickness, width and reference to the specific Siderise 'RV' linear joint seals used as cavity barrier seals, required to provide fire resistance periods in accordance with BS EN 1366-4:2006+A1:2010 for up to 120 minutes Integrity and Insulation performance for vertical applications.

The certification is only applicable to straight, linear joint seals used as cavity barriers, as those considered by BS EN 1366-4:2006+A1:2010 and does not consider corner detailing.

The products are approved on the basis of:

- i) Initial type testing.
- ii) A design appraisal against TS39.
- iii) Certification of quality management system to ISO 9001: 2015.
- iv) Inspection and surveillance of factory production control.
- v) Audit testing.

This Certificate of Approval must be read in conjunction with CERTIFIRE Technical Schedule TS39, Fire Resisting Cavity Barrier Systems.

General Requirements

The linear joint seals shall not be penetrated by services, e.g., pipes or cables.

Approved products, applications and fire resistance periods

This certificate approves the products and applications detailed within the following table subject to the installation of the products in accordance with the manufacturer's installation instructions.



CERTIFICATE No CF6028
SIDERISE INSULATION LIMITED

The approval relates linear joint gap sealing applications tested in accordance with BS EN 1366-4:2006+A1:2010. Only the specific types of constructions defined in the test reports ref may be considered as relevant to this Certification.

Page 3 of 5 Signed
E/135

Issued: 16th August 2021
Valid to: 15th August 2026

CERTIFICATE No CF6028 SIDERISE INSULATION LIMITED

Siderise 'RV' linear joint seals used as cavity barrier seals - BS EN 1366-4:2006+A1:2010

Vertical Orientation

Concrete/masonry to concrete/masonry substrates

Product	Seal Thickness (mm)	Cover Length (mm)	Compression Minimum (% or mm)	Integrity (minutes)	Insulation (minutes)	Gap Width* (mm)	Bracket Requirement*	Qty Bkts* (Min)	Max Bracket Centres* (mm)
RV-90/30	75	1200	10 %	90	30	20-50	N/A	0	N/A
RV-90/30	75	1200	Gap Width +10mm	90	30	51-150	B65/110	2	600
						151-240	B195		
						241-300	B355		
						301-450	B355		
RV-90/60	90	1200	10 %	90	60	20-50	N/A	0	N/A
RV-90/60	90	1200	Gap Width +10mm	90	60	51-150	B65/110	2	600
						151-240	B195		
						241-450	B355		
RV-120/120	120	1200	10 %	120	120	20-50	N/A	0	N/A
RV-120/120	120	1200	Gap Width +10mm	120	120	51-150	B65/110	2	600
						151-240	B195		
						241-450	B355		

*Refer to the Siderise 'RV' linear joint seals used as cavity barrier seals installation details and gap stability limitations section for further information.

Siderise 'RV' linear joint seals used as cavity barrier seals may be fitted between a minimum 150mm, thick concrete or masonry (twin leaf cavity wall) substrates of a density $\geq 670\text{kg/m}^3$.

The Certificated scope for the Siderise 'RV' linear joint seals used as cavity barrier seals has been derived from fire resistance testing in accordance with BS EN 1366-4:2006+A1:2010. For specific installation and construction details the following test reports should be utilised:

WF 389382 Issue 3
WF 398827
WF 424701
WF 412180
WF 431532



CERTIFICATE No CF6028

SIDERISE INSULATION LIMITED

Siderise 'RV' linear joint seals used as cavity barrier seals installation details and gap stability limitations

Installation and fixing

The products are supplied either pre-cut or in sheet form to allow site cutting. Care shall be taken to ensure that the required over sizing of the linear joint seals is accounted for in order to achieve the specified compression given in the tables. The compression requirements must be strictly observed.

Unless otherwise indicated the seals shall be correctly supported by steel brackets supplied by the manufacturer in compliance with the required bracket type and frequency detailed in the tables. The bracket centres shall be such that they are installed to a maximum of 300mm from each end of a 1200mm section. Brackets shall be pushed into the seal such that it is impaled at mid-thickness, with one leg extending to nominally 75% of the gap width. The steel angle brackets should be fixed with suitable fire rated fixings, which are a minimum of 7 mm in diameter and 50 mm in length. A minimum of two brackets are required for each section of linear joint seal used as a cavity barrier and short lengths of seal should be avoided, where possible.

The certification is only applicable to straight linear joint seals used as cavity barriers, as those considered by BS EN 1366-4:2006+A1:2010, and does not consider corner detailing.

Jointing

The joints between the lengths of seals shall be straight butt joints and shall be fitted in slight compression so that they are tight. RFT120/45 self-adhesive reinforced aluminium foil tape shall be applied over the joints.

Gap Stability

The gap stability is a fundamental requirement in order to achieve fire compartmentation when utilising these products and it should be noted that the fire stops will only function to the specified rating providing the gap stability does not deviate greater than the specified compression tolerances stated in the tables. Appropriate external façade support systems should be designed and installed to limit this potential movement at the elevated temperatures of a fire and, should the gap increase beyond these tolerances and or fail completely in the event of a fire, then the fire stop will cease to function.

The approval relates to on going production. Products and/or their immediate packaging are identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number (i.e. No. CF xxx) and application where appropriate.

Further Information

Further information regarding the details contained in this certificate may be obtained from Siderise Insulation Limited (Tel: 01656 730833).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 5 of 5 Signed
E/135

Issued: 16th August 2021
Valid to: 15th August 2026